



Bromley House, Barlow Drive
Woodford Park Industrial Estate
Winsford, Cheshire, CW7 2JZ
Tel: +44 (0)1606 590000
Fax: +44 (0)1606 590100
Email: sales@vaseco.com
Web: http://www.vaseco.com

Certificate of Testing.


Certificate Number: CT990286
Customer: Tomoe Tritec Limited
Order Number: 724439
Component: 10" 600lb Butterfly Control Valve
Component Test Pressure: 99 Barg
Component Test Temperature: Ambient to minus 46°c
Test Specification: WP004/141 Issue E 17/10/05
Referenced Standard: ISO 15848-1
Test Medium: Helium
Tightness Class: BH
Cycle Class: CC1
Test Date: 26th May 2006 to 2nd June 2006
Test Equipment: Mass Spectrometer: 00001005082 and 90001028127
Pressure Transducer & Display s/n: 1509624
Thermocouple: 0011299, 0011300 and 0011301




Results: As per attached Vaseco Leak Rate Manager File and Chart Recording.

Stem Seal Adjustment: SSA-1: 1st Low Temperature Cycle

Body Seal Leakage: No Recordable Leakage

Test Completed By: .....

Date: 2-6-2006

Test Witnessed By: .....
CTISS

Date: 02/06/2006